

REPORT

ON

DETAILED ENERGY AUDIT

Conducted at



**M/s GMR INSTITUTE OF
TECHNOLOGY**

**Rajam, Srikakulam District,
Andhra Pradesh 532127**

Conducted by

Energy Auditing Firm



EAST COAST SUSTAINABLE PRIVATE LIMITED

6-80/1, PRIYA GARDENS P.O SIMHACHALAM, VISAKHAPATNAM

ANDHRA PRADESH – 530028

CIN: U74999AP2018PTC108807

www.eastcoast.net.in

August-2021

1 Table of Contents

| | | |
|-------------|---|------------|
| I. | ACKNOWLEDGEMENT | i |
| II. | ENERGY AUDIT TEAM..... | ii |
| III. | EXECUTIVE SUMMARY | iii |
| IV. | LIST OF ENERGY CONSERVATION RECOMMENDATIONS..... | iv |
| V. | IMPORTANT INFORMATION | v |
| 1 | INTRODUCTION | 8 |
| 1.1 | GENERAL DETAILS | 8 |
| 1.2 | SCOPE OF THE STUDY: | 8 |
| 2 | DESCRIPTION OF ENERGY SYSTEMS..... | 9 |
| 2.1 | ENERGY SYSTEMS DESCRIPTION | 9 |
| 2.2 | ELECTRICAL ENERGY ANALYSIS | 9 |
| 2.2.1 | RECORDED MAXIMUM DEMAND PATTERN | 11 |
| 2.2.2 | ELECTRICITY CONSUMPTION PATTERN | 11 |
| 2.3 | WATER SYSTEM..... | 12 |
| 2.4 | CAPACTOR DETAILS..... | 12 |
| 2.5 | TRANSFORMER LOAD MANAGEMENT..... | 13 |
| 2.6 | ENERGY DISTRIBUTION | 13 |
| 2.7 | ENERGY DISTRIBUTION OF DIFFERENT BLOCKS..... | 15 |
| 2.8 | PUMPS | 28 |

LIST OF TABLES

| | |
|--|-----|
| TABLE 1: LIST OF ENERGY SAVING RECOMMENDATIONS..... | IV |
| TABLE 2: LIST OF ELECTRICITY CONSUMPTION DETAILS..... | V |
| TABLE 3: DIESEL CONSUMPTION DETAILS..... | VI |
| TABLE 4: WATER CONSUMPTION DETAILS..... | VI |
| TABLE 5: ELECTRICAL & SOLAR CONSUMPTION DETAILS..... | VII |
| TABLE 6: MONTH WISE ELECTRICITY CONSUMPTION APRIL 2020 – MARCH 2021..... | 10 |
| TABLE 7: WATER STORAGE DETAILS..... | 12 |
| TABLE 8: ENERGY SHARE PATTERN..... | 13 |
| TABLE 9: BLOCK-1 ENERGY SHARE PATTERN..... | 15 |
| TABLE 10: BLOCK-2 ENERGY SHARE PATTERN..... | 17 |
| TABLE 11: BLOCK-3 ENERGY SHARE PATTERN..... | 20 |
| TABLE 12: BLOCK-4 ENERGY SHARE PATTERN..... | 22 |
| TABLE 13: BLOCK-5 ENERGY SHARE PATTERN..... | 24 |
| TABLE 14: BLOCK-6 ENERGY SHARE PATTERN..... | 25 |
| TABLE 15: BOYS HOSTEL ENERGY SHARE PATTERN..... | 26 |
| TABLE 16: GIRLS HOSTEL ENERGY SHARE PATTERN..... | 27 |

LIST OF FIGURES

| | |
|--|----|
| FIGURE 1:RECORDED MAXIMUM DEMAND PATTERN..... | 11 |
| FIGURE 2: MONTH WISE ELECTRICAL CONSUMPTION PATTERN..... | 11 |
| FIGURE 3: % OF ENERGY SHARE PATTERN..... | 14 |
| FIGURE 4: BLOCK-1 % OF ENERGY SHARE PATTERN..... | 16 |
| FIGURE 5: BLOCK-2 % OF ENERGY SHARE PATTERN..... | 19 |
| FIGURE 6: BLOCK-3 % OF ENERGY SHARE PATTERN..... | 21 |
| FIGURE 7: BLOCK-4 % OF ENERGY SHARE PATTERN..... | 23 |
| FIGURE 8: BLOCK-5 % OF ENERGY SHARE PATTERN..... | 24 |
| FIGURE 9: BLOCK-6 % OF ENERGY SHARE PATTERN..... | 25 |
| FIGURE 10: BOYS HOSTEL % OF ENERGY SHARE PATTERN..... | 26 |
| FIGURE 11: GIRLS HOSTEL % OF ENERGY SHARE PATTERN..... | 27 |

I. ACKNOWLEDGEMENT

THE ENERGY AUDIT TEAM appreciates the keen interest shown by the management of **GMR INSTITUTE OF TECHNOLOGY, RAJAM** in getting Energy Audit done for conservation of energy.

THE ENERGY AUDIT TEAM expresses its sincere thanks to the management of “**GMR INSTITUTE OF TECHNOLOGY, RAJAM**” for their trust and entrusting the assignment of Energy Audit of **GMR INSTITUTE OF TECHNOLOGY, RAJAM**.

THE ENERGY AUDIT TEAM is grateful to **Dr. CLVRSV PRASAD**, Principal of college, for his initiative and confidence in **THE ENERGY AUDIT TEAM** in awarding the mandatory energy audit study.

We are thankful to the GMR Varalakshmi Foundation, GMRIT management for giving us the opportunity to be involved in this interesting and challenging project.

We are also extremely thankful to the below management team for their hospitality, support and guidance and co-operation in undertaking this energy audit assignment.

Dr T. S . L .V AYYARAO- Department of EEE

Mr S. RAMESH BABU – Estates Department

and all other supporting staff who have given full co-operation and support. They took keen interest and gave valuable inputs during the course of study. We would be happy to provide any further clarifications, if required, to facilitate implementation of the recommendations.

The arrangements and support during the energy audit were excellent. We deeply appreciate the interest, enthusiasm, and commitment of **GMR INSTITUTE OF TECHNOLOGY, RAJAM**. towards the energy conservation.

For

The Energy Audit Team

II. ENERGY AUDIT TEAM

| Name of the Member | Role in the Project |
|---------------------|---|
| Mr. G Srinivasa Rao | Team Leader - Accredited Energy Auditor |
| Mr. Azmal Basha | Team Member - Energy Auditor |

The report is made as per the Bureau of Energy Efficiency (BEE), Ministry of Power, and Govt. of India format.

III. EXECUTIVE SUMMARY

East Coast sustainable (P). Ltd has been entrusted with carrying out “Detailed Energy Audit” in Head- Office of M/s GMR Institute of Technology, Rajam. optimize the energy consumption and to identify the energy saving opportunities in the facility. In this connection, East Coast has conducted field measurements at the facility during August 2021 for collection of data and measuring various energy consumption parameters to analyse and find energy saving opportunities.

The major energy inputs for the facility are Electricity, Diesel, and Water. Electricity is used for Package Air Conditioners, Severs, PCs, ACs, Fans, lighting appliances and other loads. Diesel oil is being used in the DG set to generate electricity during power failure. A detailed study was carried out with an objective to identify and prioritize the cost-effective energy conservation recommendations to decrease the energy consumption and energy costs in the facility.

GMR Institute of Technology Installed 700 kW grid-connected solar PV system available for the benefit of campus.

Grid-connected solar PV systems feed solar energy directly into the building loads without battery storage. Surplus energy, if any, is exported to the APEPDCL grid and shortfall, if any, is imported from the grid.

IV. LIST OF ENERGY CONSERVATION RECOMMENDATIONS

The following are the energy conservation recommendations identified in the facility.

Table 1: List of Energy Saving Recommendations

| S. No | Name of the recommendation | Savings (kWh/year) | Monetary Savings (Rs./year) | Investment (Rs.) | Payback period (Months) | Remarks |
|-------|--|--------------------|-----------------------------|------------------|-------------------------|---------|
| 1 | Recommended to check with the authorized service person to improve the performance of the AC'S | 55200 | 422280 | NA | NA | |
| 2 | Retrofit T12& T8tube lights with LED Tube Light | 28100 | 213566 | 868500 | 48 | |

V. IMPORTANT INFORMATION

- a) Name and Address of the plant : M/s GMR Institute of Technology
Rajam, Srikakulam District,
Andhra Pradesh 532127
India
- b) Line of Activity : Educational Institutional
- c) Contact Person and Details : Dr.T.S.L.V. Ayya Rao
Phone: +91- 8074821496
E-mail: ayyarao.tslv@gmrit.edu.in
- d) Period of Audit : August-2021
- e) Contracted Maximum Demand (CMD) : 600 kVA
- f) Maximum Recorded Demand (M.D) : 352 kVA (March-2021)
- g) Minimum Recorded Demand (M.D) : 147 kVA (August-2020)
- h) Power factor (PF) : 0.99 (Avg.)
- i) Energy Consumption & their cost details :

Table 2: List of Electricity Consumption details

| Electricity Consumption details for April 2020- March 2021 | | | |
|--|--|----------------------|----------|
| Cost of Electricity | | : Rs. 7.65/Unit Kvah | |
| Demand Charges | | : Rs. 475/kVA | |
| S. No | Particulars | Unit | Value |
| 1 | Monthly Avg. Consumption of Electricity | kvah/Month | 98132 |
| 2 | Monthly Avg. Bill of Electricity | Rs./ Month | 961636 |
| 3 | Yearly Consumption of Electricity | kWh/Year | 1177584 |
| 4 | Yearly Bill of Electricity | Rs./ Year | 11539634 |
| 5 | Maximum Electricity Consumption (March-2021) | kvah/Month | 178410 |
| 6 | Minimum Electricity Consumption (Apr- 2020) | kvah/Month | 72493 |

Table 3: Diesel Consumption details

| Diesel Consumption Details for April 2020 – March 2021DG Set (180 +380 + 500) kVA | | | | |
|--|---------------------------|-----------------------------|-------------------------------|--|
| Month | Unit Generated kWH | Diesel Consumption L | Diesel Expenses /Month | Average power fail Hours /Month |
| 04-04-2020 | 10000 | 1,500 | 1,09,500 | 25 |
| 04-05-2020 | 16800 | 2,350 | 1,69,200 | 42 |
| 04-06-2020 | 14200 | 2,100 | 1,57,500 | 36 |
| 04-07-2020 | 6400 | 850 | 65,450 | 16 |
| 04-08-2020 | 9000 | 850 | 68,000 | 23 |
| 04-09-2020 | 7200 | 1,350 | 1,16,100 | 18 |
| 04-10-2020 | 9660 | 1,350 | 1,16,100 | 24 |
| 04-11-2020 | 4104 | 850 | 73,100 | 10 |
| 04-12-2020 | 2000 | 450 | 38,700 | 5 |
| 04-01-2021 | 1600 | 200 | 17,200 | 4 |
| 04-02-2021 | 4800 | 1,000 | 89,260 | 12 |
| 04-03-2021 | 3600 | 700 | 63,357 | 9 |
| Total | 89,364 | 13,550 | 10,83,467 | 223.41 |

Table 4: Water Consumption details

| Water Consumption Details for April 2020 – March 2021 | | | |
|--|----------------------------|-------------|--------------|
| S. No | Particulars | Unit | Value |
| | | | Water |
| 1 | Yearly Water. Consumption | KL/year | 8500 |
| 2 | Monthly Water. Consumption | KL/Day | 708 |
| 3 | Daily Water Consumption | KL/Day | 29 |

Table 5: Electrical & Solar Consumption details

| Solar & Electrical Consumption details for April 2020- March 2021 | | | | |
|--|-----------------------------|--------------------------------|---------------------------|-----------------------|
| Month | EB Power Bill Energy | Solar Power Bill Energy | Solar Export to EB | Consumed Units |
| Apr-20 | 43822 | 72737 | 44066 | 72493 |
| May-20 | 50727 | 75172 | 39834 | 86065 |
| Jun-20 | 49666 | 64748 | 23920 | 90494 |
| Jul-20 | 49341 | 72577 | 37446 | 84472 |
| Aug-20 | 48551 | 63898 | 34228 | 78221 |
| Sep-20 | 56082 | 72396 | 34315 | 94163 |
| Oct-20 | 56688 | 62273 | 30455 | 88506 |
| Nov-20 | 45827 | 71960 | 38065 | 79722 |
| Dec-20 | 59107 | 90170 | 50191 | 99086 |
| Jan-21 | 55153 | 83866 | 45611 | 93408 |
| Feb-21 | 76911 | 89173 | 33540 | 132544 |
| Mar-21 | 107397 | 90099 | 19086 | 178410 |
| Total | 699272 | 909069 | 386691 | 1177584 |

1 INTRODUCTION

1.1 GENERAL DETAILS

GMR Institute of Technology (GMRIT) was established in the year 1997 by GMR Varalakshmi Foundation – the corporate social responsibility arm of GMR Group. Located in Rajam, Srikakulam district of Andhra Pradesh, GMRIT provides its learning community state-of-the-art facilities, infrastructure and a competent faculty. The Institute encourages collaborative learning between industry and academia as a means of reinforcing its curriculum with practical and real world experiences.

The institute was approved by AICTE and got the status of Autonomous college under JNTU and has got accreditation by NAAC of UGC with “ A “ grade, NBA accreditation for all the UG courses being offered. The institute is offering 07 UG courses and 07 PG courses. It has a total teaching staff strength of 113 and student strength of around 3600. It has a very good library which has around 65000 volumes and 17000 books. Recently the institute was awarded the “Most Clean Campus in India in 'AICTE Clean Campus Award 2017’.

GMRIT's research potential spans over diverse disciplines like CAD/CAM, Signal Processing, Time Frequency Transform application to Non-Stationary signal Analysis, System modeling and Identification, Adaptive Filtering, Machine Intelligence, Manufacturing, Product Design, Energy, Information Technology and Structural Engineering. It encourages its researchers to participate in a wide range of research collaborations in the premier Institutes of India. GMRIT organizes various International/ National conferences and Workshops in different thrust areas to discuss and disseminate latest research findings in many burning issues to enable technology for mankind.

GMR group is very active in promoting renewable energy and energy conservation. Solar PV power plant of 700 kWp was installed at the facility. Every week on Thursday, the institute follows Zero pollution day as a social responsibility towards the environment.

The audit covered an in study of the distribution transformers, pumps, Blowers, Air conditioning system, DG set and lighting system. The energy audit covered study of all the major energy consuming equipment.

1.2 SCOPE OF THE STUDY:

The major energy consuming loads of the facility are

- HVAC (Package AC units, Split AC units, Window AC units)
- Lights and Fans
- Water Pumps and Fire Water pumps
- PCs, Servers (UPS load)

2 DESCRIPTION OF ENERGY SYSTEMS

2.1 ENERGY SYSTEMS DESCRIPTION

The major inputs for the facility are

- i. Electricity from APEPDCL,
 - ii. Diesel oil for DG sets as a backup for power and
 - iii. Water for domestic use and fire fighting
-
- Electricity is the major input energy and used for HVAC, Lighting, Pumping and running the office equipment like Servers, Computers, Printers, etc.
 - Diesel oil is used in DG sets to generate power in case of power failure.
 - Water is being used for drinking, cooking, washrooms, and firefighting.

2.2 ELECTRICAL ENERGY ANALYSIS

The electricity is sourced from APEPDCL. The following are the details of the electrical supply.

- The facility has a Maximum Contract Demand (CMD) of 600 kVA.
- The facility has installed 3 No of Transformer of capacity 2x 480 kVA
- The plant has 3 DG sets of 1x500 kVA, 1x 380 kVA & 1x 500 kVA each capacity and is used in the event of power failure.
- Grid supply is available at 11 kV and is stepped down to 415 Volts. The average power factor is maintained at 1 (avg.)
- The annual electricity consumption of plant is 1177584 kvah (Units) from Apr-2020 to March-2021. The electricity consumption is varied from 72493 kvah to 178410 kvah and the average monthly electricity consumption is 98132 kvah

M/s GMR Institute of Technology, Rajam.

Table 6: Month wise electricity consumption April 2020 – March 2021

| Electricity Bill | | | | | | | | | |
|-------------------------|------------------------------|----------------------------|--|--|--|-------------------------|--------------------------|---------------------------------|-------------|
| Month & Year | Consumed Units (Kvah) | Billed Units (kvah) | Demand Charges Rs.475/- per kva | Energy Charges Rs.7.65 per unit | Electricity Duty Re.0.06 per unit | Customer Charges | Surcharges if any | Total amount paid so far | PF |
| Apr-20 | 43822 | 12000 | 228000 | 91800 | 2629 | 1406 | 13271 | 337106.32 | 0.99 |
| May-20 | 50727 | 12000 | 228000 | 91800 | 3044 | 1406 | 7877 | 332126.62 | 1.00 |
| Jun-20 | 49666 | 25746 | 228000 | 196957 | 2980 | 1406 | 13980 | 443322.86 | 0.99 |
| Jul-20 | 49341 | 12000 | 228000 | 91800 | 2960 | 1406 | 14596 | 338762.46 | 1.00 |
| Aug-20 | 48551 | 14323 | 228000 | 109571 | 2913 | 1406 | 15109 | 356999.01 | 1.00 |
| Sep-20 | 56082 | 21767 | 228000 | 166518 | 3365 | 1406 | 15907 | 415195.47 | 1.00 |
| Oct-20 | 56688 | 26233 | 228000 | 200682 | 3401 | 1406 | 15299 | 448788.73 | 1.00 |
| Nov-20 | 45827 | 12000 | 228000 | 91800 | 2750 | 1406 | 12787 | 336742.62 | 1.00 |
| Dec-20 | 59107 | 12000 | 228000 | 91800 | 3546 | 1406 | 17183 | 341935.42 | 0.99 |
| Jan-21 | 55153 | 12000 | 228000 | 75560 | 3309 | 1406 | 16002 | 324277.24 | 0.99 |
| Feb-21 | 76911 | 43371 | 228000 | 331788 | 4615 | 1406 | 22740 | 588548.81 | 0.99 |
| Mar-21 | 107397 | 88311 | 228000 | 675579 | 6444 | 1406 | 28190 | 939618.97 | 0.97 |
| Total | 699272 | 291751 | 2736000 | 2215655 | 41956.38 | 16872 | 192941 | 5203424.5 | |
| Maximum | 107397 | 88311 | 228000 | 675579 | 6444 | 1406 | 28190 | 939619 | 1.00 |
| Minimum | 43822 | 12000 | 228000 | 75560 | 2629 | 1406 | 7877 | 324277 | 0.97 |

2.2.1 RECORDED MAXIMUM DEMAND PATTERN

The below is the recorded demand pattern of the facility from April- 2020 to March -2021.




Figure 1:Recorded Maximum Demand Pattern

2.2.2 ELECTRICITY CONSUMPTION PATTERN

The following is the electricity consumption pattern for the facility from April-2020 to March-2021. The electricity consumption is high during the April- 2021 and consumption is low in the month of March-2020.




Figure 2: Month wise electrical consumption pattern

2.3 WATER SYSTEM

Majority of water source for GMRIT campus facility is met with from their internal open wells and borewells. Apart from that, management has also made arrangement for tankers and municipal water supply board for meeting the deficit demand of entire campus. Multiple pumps of various types and capacities have installed across the different location of campus for water transportation. Facility has two bulk water storage reservoir one at underground level sump (UGLSR) of 2,50,000 litres capacity and other overhead tank (OHT) of 2,00,000 liters capacity. Further from the overhead tank, water pipe lines of different size (1.5”, 2” and 3”) are drawn for gravity distribution to different blocks of hostels, quarters, Degree College, etc. Several tanks are installed at individual building blocks of campus for water storage and regulated utilization. Location of the GMRIT pumps along with their sources are given.

Table 7: Water Storage Details

| Pump Identification | Type |
|------------------------|-------------|
| GCSR College | Open well |
| GMR Care Back Side | Open well |
| CSE Block | Open well |
| OHT sump pump -1 | Submersible |
| OHT sump pump -2 | Submersible |
| Principle | Open well |
| RASA quarters | Open well |
| Boys Hostel sump | Sump |
| STP treated water sump | Sump |

2.4 CAPACTOR DETAILS

The plant has installed a total capacitor banks of 210 KVAR mainly to reduce the kVA demand of the facility. The capacity breakup details are provided below:

- SS-1 : $2 \times 25 + 2 \times 20 + 3 \times 10 = 120$ kVAR
- SS-2 : $2 \times 20 + 1 \times 30 = 70$ kVAR
- STP : $1 \times 20 = 20$ kVAR

2.5 TRANSFORMER LOAD MANAGEMENT

Based on the loading pattern of the main transformers, the following parameters like percentage loading, Best efficiency point and all day efficiency are calculated and the details are given in the table 4.13. Table 4.13 Transformer performance parameters

| Transformer-1 | Transformer-2 | Transformer rating (kVA) | No load losses (kW) | Full load losses (kW) | Average load (kVA) | Maximum load (kVA) | Best Efficiency point (%) | Loading (%) | Annual No load losses (kWh) | Annual full load losses (kWh) | Annual Total losses(kWh) | | | | | | |
|---------------|---------------|--------------------------|---------------------|-----------------------|--------------------|--------------------|---------------------------|-------------|-----------------------------|-------------------------------|--------------------------|------|------|-------|-------|-------|-------|
| 480 | 500 | 1.15 | 1.25 | 7.15 | 7.45 | 89.0 | 151.2 | 155.6 | 200.1 | 40.1 | 41.0 | 32.4 | 40.0 | 10074 | 10950 | 14675 | 18263 |

Combined transformer losses/year 32938 From the above transformer load analysis, it is seen that the load on the transformer is operating less than its ‘Best operating point‘ or ‘Optimal loading point‘ and transformer operating losses are on minimum side. The annual transformer losses accounts to 1.5% of the total facility annual energy consumption.

2.6 ENERGY DISTRIBUTION

The distribution of electricity is presented in the following pie-chart.

The % of energy share pattern is as given below:

Table 8: Energy share pattern

| Sl.No | Block Name | Power (KW) | % of Energy Share |
|-------|-------------------|-------------|-------------------|
| 1 | Block -1 | 395 | 16% |
| 2 | Block -2 | 205 | 8% |
| 3 | Block -3 | 278 | 11% |
| 4 | Block -4 | 271 | 11% |
| 5 | Block -5 | 169 | 7% |
| 6 | Block -6 | 73 | 3% |
| 7 | SGCSRC | 53 | 2% |
| 8 | Work Shop | 113 | 5% |
| 9 | Siemens Work Shop | 46 | 2% |
| 10 | Staff Qarters | 460 | 18% |
| 11 | Girls Hostel | 132 | 5% |
| 12 | Boys Hostel | 240 | 10% |
| 13 | Estate Complex | 20 | 1% |
| 14 | CSW | 19 | 1% |
| 15 | Street Light | 20 | 1% |
| 16 | Total | 2494 | 100% |




Figure 3: % of Energy share pattern

2.7 ENERGY DISTRIBUTION OF DIFFERENT BLOCKS

The distribution of electricity is presented in the following pie-chart.

The % of energy share pattern is as given below:

Table 9: Block-1 Energy share pattern

| Sl.No | Appliance | Power (KW) | % Sharing of Power |
|-------|--------------|------------|--------------------|
| 1 | Tensile.M | 1 | 0.25% |
| 2 | C Fans | 6.525 | 1.65% |
| 3 | AC 2 T | 76 | 19.24% |
| 4 | CFL 36 W | 3.6 | 0.91% |
| 5 | Computers | 115.5 | 29.24% |
| 6 | Ex Fans | 0.715 | 0.18% |
| 7 | UPS | 83 | 21.01% |
| 8 | W Fan | 4.095 | 1.04% |
| 9 | P. Point | 1.3 | 0.33% |
| 10 | Cooler | 1 | 0.25% |
| 11 | Freezer | 0.5 | 0.13% |
| 12 | 2x2 LED | 0.38 | 0.10% |
| 13 | T Lights | 11.66 | 2.95% |
| 14 | TV | 0.3 | 0.08% |
| 15 | 2x2 Lights | 0.36 | 0.09% |
| 16 | LED | 0.228 | 0.06% |
| 17 | LED | 0.014 | 0.00% |
| 18 | AC 1.5 T | 1.5 | 0.38% |
| 19 | AC 7.5 T | 6 | 1.52% |
| 20 | SV Lamp | 0.15 | 0.04% |
| 21 | CFL 11 W | 0.198 | 0.05% |
| 22 | EPABX | 0.3 | 0.08% |
| 23 | Fax | 0.1 | 0.03% |
| 24 | Heater | 2 | 0.51% |
| 25 | MH 70 | 0.07 | 0.02% |
| 26 | Printer | 0.7 | 0.18% |
| 27 | Xerox | 0.5 | 0.13% |
| | Total | 395 | 100% |

Figure 4: Block-1 % of Energy share pattern




Table 10: Block-2 Energy share pattern

| SI.No | Appliance | Power (KW) | % Sharing of Power |
|-------|-----------------------|------------|--------------------|
| 1 | T.Lights | 9.405 | 4.61% |
| 2 | UPS-10KVA | 9 | 4.41% |
| 3 | UPS-15KVA | 13.5 | 6.61% |
| 4 | UPS-5KVA | 13.5 | 6.61% |
| 5 | W.F-12" | 2.21 | 1.08% |
| 6 | 5A.P.Point | 1.86 | 0.91% |
| 7 | AC-1.5T | 6 | 2.94% |
| 8 | AC-1T | 1 | 0.49% |
| 9 | AC-2T | 22 | 10.77% |
| 10 | All Geared lahte | 11 | 5.39% |
| 11 | Bench Grinder | 0.37 | 0.18% |
| 12 | Benelious.apa | 0.37 | 0.18% |
| 13 | C.Fans | 9.675 | 4.74% |
| 14 | Calibrating-N | 0.735 | 0.36% |
| 15 | Capstan Lahte | 0.735 | 0.36% |
| 16 | Centrifugal.p | 5.5 | 2.69% |
| 17 | CFL-11w | 0.176 | 0.09% |
| 18 | CFL-18W | 0.0018 | 0.00% |
| 19 | CFL-36W | 1.08 | 0.53% |
| 20 | CNC lath | 1.5 | 0.73% |
| 21 | CNC-Mill | 1.5 | 0.73% |
| 22 | Compressor | 0.56 | 0.27% |
| 23 | Computers | 36.3 | 17.77% |
| 24 | Corist action shacker | 0.017 | 0.01% |
| 25 | Printers | 0.3 | 0.15% |
| 26 | PLC-1 | 0.3 | 0.15% |
| 27 | PLC-2 | 0.3 | 0.15% |
| 28 | Induction-M | 0.18 | 0.09% |
| 29 | Muf.Furnace | 3.5 | 1.71% |
| 30 | Jammy test | 0.735 | 0.36% |
| 31 | Metolograpy | 0.37 | 0.18% |
| 32 | Disk polish-1 | 0.74 | 0.36% |
| 33 | Disk polish-2 | 0.74 | 0.36% |
| 34 | Pitot tube | 0.37 | 0.18% |
| 35 | Helical coil | 0.37 | 0.18% |
| 36 | Reciprocating | 0.735 | 0.36% |
| 37 | Mouth piece | 0.735 | 0.36% |
| 38 | Friction in pipe | 0.735 | 0.36% |
| 39 | Orifice.Meter | 0.735 | 0.36% |
| 40 | Packed bed | 0.37 | 0.18% |
| 41 | Input.j.vane | 0.735 | 0.36% |
| 42 | Fluidised bed | 0.37 | 0.18% |
| 43 | Rota meter | 0.75 | 0.37% |
| 44 | Francis Turbine | 5.5 | 2.69% |
| 45 | Non circular.pipes | 0.37 | 0.18% |

M/s GMR Institute of Technology, Rajam.

| | | | |
|----|-------------------------------------|-----------------|-------------|
| 46 | Pin fin apparatus | 0.37 | 0.18% |
| 47 | Stefan Boltz | 1 | 0.49% |
| 48 | Detormination | 1 | 0.49% |
| 49 | Critical Heat flux | 1 | 0.49% |
| 50 | Heat pipe apparatus | 1 | 0.49% |
| 51 | Fridge | 0.45 | 0.22% |
| 52 | Drop and Film | 0.125 | 0.06% |
| 53 | Heat Transfer through Coils | 2 | 0.98% |
| 54 | Double pipe Heat Exchanger | 2 | 0.98% |
| 55 | Legged pipe apparatus | 1 | 0.49% |
| 56 | Heat Transfer to Composit wall | 1 | 0.49% |
| 57 | Forced convection apparatus | 0.37 | 0.18% |
| 58 | PL-4 Lathe | 0.735 | 0.36% |
| 59 | Shaping Machine | 2.2 | 1.08% |
| 60 | Shaping Machine | 1.47 | 0.72% |
| 61 | Surphase grinder | 0.735 | 0.36% |
| 62 | Power Hack saw | 2.94 | 1.44% |
| 63 | Pilla Drilling machine | 0.37 | 0.18% |
| 64 | Radial Drilling machine | 4.4 | 2.15% |
| 65 | Motor | 0.18 | 0.09% |
| 66 | Heaters | 8 | 3.92% |
| 67 | Mixed Flow reactor | 0.051 | 0.02% |
| 68 | Solid liquid with chemical reaction | 0.517 | 0.25% |
| 69 | CSTR | 0.017 | 0.01% |
| 70 | Stirrer | 0.017 | 0.01% |
| 71 | Forced draft drain | 0.37 | 0.18% |
| 72 | Surface evaporation | 0.117 | 0.06% |
| 73 | Steam distillation | 0.5 | 0.24% |
| 74 | Diffusion | 0.017 | 0.01% |
| 75 | Thermal Conductivity | 0.5 | 0.24% |
| 76 | Thermal Conductivity of Metal Rod | 1 | 0.49% |
| 77 | Universal milling | 1.47 | 0.72% |
| 78 | Tool &Cutter Grinder | 0.37 | 0.18% |
| | Total | 204.2258 | 100% |

Figure 5: Block-2 % of Energy share pattern




Table 11: Block-3 Energy share pattern

| Sl.No | Appliance | Power (KW) | % Sharing of Power |
|-------|-------------------------------|----------------|--------------------|
| 1 | CFL | 0.432 | 0.15% |
| 2 | CFL-11W | 0.066 | 0.02% |
| 3 | CFL2x36W | 1.296 | 0.46% |
| 4 | CFL-18W | 0.072 | 0.03% |
| 5 | CFL-11W | 0.22 | 0.08% |
| 6 | C.Fans | 11.625 | 4.16% |
| 7 | AC-1T | 2 | 0.72% |
| 8 | AC-1.5T | 7.5 | 2.68% |
| 9 | AC-2T | 28 | 10.01% |
| 10 | 5A.P.Point | 4.74 | 1.70% |
| 11 | 15A.P.Point | 0.5 | 0.18% |
| 12 | Stabilizer | 9 | 3.22% |
| 13 | Synchronous motor-5hp | 3.73 | 1.33% |
| 14 | Slop Induction Motor | 3.73 | 1.33% |
| 15 | Squirel cage Induction Motor | 3.73 | 1.33% |
| 16 | Case cad Induction Motor | 3.73 | 1.33% |
| 17 | DC Compound Motor | 7.5 | 2.68% |
| 18 | DC Shunt Motor 2 | 7.5 | 2.68% |
| 19 | DC.Series Motor | 3 | 1.07% |
| 20 | DC.Shunt Motor-1 | 2.238 | 0.80% |
| 21 | DC.Shunt Motor-2 | 2.238 | 0.80% |
| 22 | DC.Shunt Motor-Generator Set | 2 | 0.72% |
| 23 | DC.Shunt Motor-Series Gen set | 2.238 | 0.80% |
| 24 | DC Compound Motor-Genset | 1.5 | 0.54% |
| 25 | 1Phase induction Motor | 0.75 | 0.27% |
| 26 | DC.Shunt Motor -Genset | 2.238 | 0.80% |
| 27 | DC.Compound Motor | 2.238 | 0.80% |
| 28 | Tranformers-2KVA | 1.8 | 0.64% |
| 29 | Tranformers-1KVA | 5.4 | 1.93% |
| 30 | Transformer-3KVA | 13.5 | 4.83% |
| 31 | Transformer-2.5KVA | 9 | 3.22% |
| 32 | 1Phase induction Motor | 1.5 | 0.54% |
| 33 | Case cad Induction Motor | 7.46 | 2.67% |
| 34 | UPS-20KVA | 36 | 12.87% |
| 35 | UPS-20KVA | 54 | 19.31% |
| 36 | UPS-7.5KVA | 13.5 | 4.83% |
| 37 | UPS-7.5KVA | 13.5 | 4.83% |
| 38 | W.F-12" | 2.275 | 0.81% |
| 39 | Computers | 7.878 | 2.82% |
| | Total | 279.624 | 100% |

Table 12: Block-4 Energy share pattern

| Sl.No | Appliance | Power (KW) | % Sharing of Power |
|--------------|------------------|-------------------|---------------------------|
| 1 | Parkans | 7.8 | 2.88% |
| 2 | Hologen | 9 | 3.33% |
| 3 | Babycans | 2 | 0.74% |
| 4 | Spotlight | 2.6 | 0.96% |
| 5 | Hologen | 3 | 1.11% |
| 6 | Scanners | 1.2 | 0.44% |
| 7 | Projector | 0.8 | 0.30% |
| 8 | Water Coller | 2 | 0.74% |
| 9 | W.F-12" | 2.925 | 1.08% |
| 10 | UPS-7.5KVA | 6.75 | 2.49% |
| 11 | UPS-10KVA | 18 | 6.65% |
| 12 | UPS-5KVA | 4.5 | 1.66% |
| 13 | T.V | 0.3 | 0.11% |
| 14 | T.Lights | 5.94 | 2.19% |
| 15 | Stabilizer | 75 | 27.71% |
| 16 | LED-2x2 | 0.304 | 0.11% |
| 17 | LED-70watt | 0.28 | 0.10% |
| 18 | Ex.Fans | 0.65 | 0.24% |
| 19 | Computers | 19.2 | 7.09% |
| 20 | Hologen | 9 | 3.33% |
| 21 | Hologen | 4 | 1.48% |
| 22 | CFL-18W | 1.476 | 0.55% |
| 23 | CFL-11W | 0.297 | 0.11% |
| 24 | CFL-36W | 3.456 | 1.28% |
| 25 | CFL-55W | 1.32 | 0.49% |
| 26 | C.Fans | 7.125 | 2.63% |
| 27 | Babycans | 3 | 1.11% |
| 28 | AC-2T | 16 | 5.91% |
| 29 | AC-1T | 8 | 2.96% |
| 31 | AC-1.5T | 6 | 2.22% |
| 32 | AC-11.5T | 34.5 | 12.75% |
| 33 | 5A.P.Point | 8.4 | 3.10% |
| 34 | 15A.P.Point | 4 | 1.48% |
| 35 | 2x2 led | 1.824 | 0.67% |
| | Total | 270.647 | 100% |




Figure 7: Block-4 % of Energy share pattern

Table 13: Block-5 Energy share pattern

| Sl.No | Appliance | Power (KW) | % Sharing of Power |
|-------|--------------|----------------|--------------------|
| 1 | W.Fan-12" | 0.13 | 0.08% |
| 2 | W.Fan-16" | 0.525 | 0.31% |
| 3 | UPS | 13.5 | 8.02% |
| 4 | UPS | 18 | 10.69% |
| 5 | T.Lights | 10.285 | 6.11% |
| 6 | Submercible | 2.2 | 1.31% |
| 7 | S.V.Lamps | 0.5 | 0.30% |
| 8 | Ex.Fan-12" | 0.325 | 0.19% |
| 9 | Computers | 43.5 | 25.83% |
| 10 | CFL | 3.384 | 2.01% |
| 11 | C.Fan | 13.875 | 8.24% |
| 12 | AC | 3 | 1.78% |
| 13 | AC | 32 | 19.00% |
| 14 | AC | 20 | 11.87% |
| 15 | 5A.P.Point | 7.2 | 4.27% |
| | Total | 168.424 | 100% |




Figure 8: Block-5 % of Energy share pattern

Table 14: Block-6 Energy share pattern

| Sl.No | Appliance | Power (KW) | % Sharing of Power |
|-------|--------------|--------------|--------------------|
| 1 | Xerox | 0.5 | 0.69% |
| 2 | Water Cooler | 0.5 | 0.69% |
| 3 | W.Fan-12" | 0.13 | 0.18% |
| 4 | UPS | 1.5 | 2.07% |
| 5 | UPS | 9 | 12.43% |
| 6 | UPS | 5.4 | 7.46% |
| 7 | T.V | 0.3 | 0.41% |
| 8 | T.Lights | 8.8 | 12.16% |
| 9 | MH | 0.5 | 0.69% |
| 10 | Lamps | 0.036 | 0.05% |
| 11 | Ex.Fan | 0.065 | 0.09% |
| 12 | Computers | 17.1 | 23.62% |
| 13 | CFL | 0.144 | 0.20% |
| 14 | C.Fans | 8.175 | 11.29% |
| 15 | AC | 2 | 2.76% |
| 16 | AC | 7.5 | 10.36% |
| 17 | 5A.P.Point | 10.74 | 14.84% |
| | Total | 72.39 | 100% |




Figure 9: Block-6 % of Energy share pattern

Table 15: Boys Hostel Energy share pattern

| SL.No | Appliance | Power (KW) | % Sharing of Power |
|-------|------------------|------------|--------------------|
| 1 | C Fans | 57.15 | 23.71% |
| 2 | AC | 2 | 0.83% |
| 3 | CFL | 2.629 | 1.09% |
| 4 | Ex Fans | 2.925 | 1.21% |
| 5 | W Fan | 0.26 | 0.11% |
| 6 | P. Point | 72.24 | 29.97% |
| 7 | Cooler | 0.5 | 0.21% |
| 8 | Lamp | 8.244 | 3.42% |
| 9 | T Lights | 44.055 | 18.27% |
| 10 | TV | 0.25 | 0.10% |
| 11 | Cold Storage | 2 | 0.83% |
| 12 | Greaser | 16 | 6.64% |
| 13 | Grinders | 3 | 1.24% |
| 14 | Heating Elements | 20 | 8.30% |
| 15 | Pesto | 0.165 | 0.07% |
| 16 | Potato Piller | 2.25 | 0.93% |
| 17 | Stablizer | 5.4 | 2.24% |
| 18 | SV lamps | 2 | 0.83% |
| | Total | 241 | 100% |




Figure 10: Boys Hostel % of Energy share pattern

Table 16: Girls Hostel Energy share pattern

| SI.No | Appliance | Power (KW) | % Sharing of Power |
|-------|------------------|----------------|--------------------|
| 1 | CFL | 0.616 | 0.46% |
| 2 | Ex Fans | 1.82 | 1.37% |
| 3 | W Fan | 0.52 | 0.39% |
| 4 | P. Point | 46.8 | 35.19% |
| 5 | Cooler | 0.5 | 0.38% |
| 6 | Lamp | 2.7 | 2.03% |
| 7 | T Lights | 19.965 | 15.01% |
| 8 | TV | 0.25 | 0.19% |
| 9 | Cold Storage | 2 | 1.50% |
| 10 | Greaser | 6 | 4.51% |
| 11 | Grinders | 3 | 2.26% |
| 12 | Heating Elements | 20 | 15.04% |
| 13 | Pesto | 0.275 | 0.21% |
| 14 | Potato Piller | 0.75 | 0.56% |
| 15 | Stablizer | 10.8 | 8.12% |
| 16 | SV lamps | 2.5 | 1.88% |
| 17 | Oven | 0.5 | 0.38% |
| 18 | UPS | 1 | 0.75% |
| 19 | UPS | 9 | 6.77% |
| 20 | Water Cooler | 4 | 3.01% |
| | Total | 132.996 | 100% |




Figure 11: Girls Hostel % of Energy share pattern

2.8 PUMPS

During the audit it was observed that, 9 pumps are installed in the Campus. 7 pumps are centrifugal, and 2 pumps are Submersible is in operation. The details of the pumps are presented below:

| Pump Identification | Type | Flow m3/hr | Pressure Mtrs | Power kW |
|------------------------|-------------|------------|---------------|----------|
| GCSR college | Open well | 8 | 29 | 5 |
| GMR care back side | Open well | 29 | 14 | 5 |
| CSE Block | Open well | 6 | 13 | 2 |
| OHT Sump -1 | Submersible | 35 | 18 | 6.5 |
| OHT Sump -2 | Submersible | 35 | 23 | 8.1 |
| Principle | Open well | 16 | 11 | 5 |
| RASA Qarters | Open well | 9 | 19 | 2 |
| Boys Hostel Sump | Sump | 12 | 19 | 5.3 |
| STP Treated Water Sump | Sump | 19 | 25 | 4.6 |

GCSR College open well: One submersible pump (7.5HP) is installed in (30ft dia x 30ft deep) open well. Normally operates continuously 24 hours in a day for supplying water to UGLSR at central locality of GMRIT campus. Estimated efficiency was found to be very low mainly due to ageing of pump and suspected silt accumulation near the foot valves leading restricted flow.

GMR Care: One submersible pump (7.5HP) is installed in (20ft dia x 25ft deep) open well and normally operates 8-12 hours in a day for supplying water to GMR care and Tanker filling operations. Estimated efficiency was found to be low due to higher velocity as the installed pipeline is found to be very small.

CSE Block Open well: One submersible pump (5HP) is installed in (15ft dia x 30ft deep) open well and normally operates 12 hours in a day for supplying water to UGLSR at central locality of GMRIT campus. Estimated efficiency was found to be low due to ageing and performance deterioration after re-wounded motor twice in the past.

Underground sump: Two submersible pumps (7.5HP) is installed in (30ft dia x 12ft deep) closed reservoir. Normally one pump operates continuously 24 hours in a day to fill the overhead tank, while other pump at standby mode. Estimated efficiency of both the pumps was found to be low, it is mainly due to mismatch in design consideration for present operation. Observed physical height of OHT tank is 16m and frictional head of installed 3” pipelines & valves are around 2-3 m. Total head required is around 18-20m, but design specifications (Flow-77 m³ /h, Head-10m, Power-5.5 kW) of pump are leading to operate in efficient zone. This scenario has reduced flow delivery to

50% of design and power consumption of motor to overloading. It was also known from the operating personnel, that one of the pump is designed with additional stage for head development.

Principal quarter's backside: One submersible pump (7.5HP) is installed in (20ft dia x 30 ft deep) open well. Normally pump operation is 8 hours in a day for supplying water to UGLSR at central locality of GMRIT campus. Estimated efficiency was found to be low, mainly due to depleted water levels in the well and mismatch in design and operation.

Rasa quarters: One submersible pump (3HP) is installed in (10ft x 20ft) sump of 30000 liters capacity. Normally pump operates for 8 hours in a day by lifting water from sump to overhead tank located at building's top floor (70 ft). Further water is distributed to individual houses by gravity through connected pipelines. Estimated efficiency was found to be slightly on the lower side, due to throttling of discharge valve at user end for avoiding overflow.

Boys Hostel sump: One submersible pump (5HP) is installed in (10ft x 30 ft) sump of 30000 liters capacity. Normally pump operates for 10-14 hours in a day by lifting water from sump to multiple overhead storage tanks located at different hostel building blocks top floor (40-60 ft). Further water is distributed to individual solar water heaters by gravity through connected pipelines. Estimated efficiency was found to be on the lower side, it is mainly due to mismatch in design consideration and present head variation for different hostel blocks.

Sewage treatment plant pump: One submersible pump (5HP) is installed in (20ft dia x 30 ft deep) open well. Normally pump operates for 12 hours in a day by lifting treated water from sump to direct distribution of gardening purpose for sprinkler system. Estimated efficiency was found to be slightly on the lower side, mainly due to restricted flow and variation in consumption near the user ends.

2.9 10.4 Canteen

During the canteen (boys & girls hostel) study, we came across the following observations

- LPG is the main source of energy for cooking and hot water generation, with consumption of total 10-12 cylinders (Boys – 6/8, Girls -2 and canteen-2) in a day.
- One deep freezer will be continuously operating for cold storage of vegetables at 8oC. whereas the exhaust blower resumes operation during cooking.

- Small capacity boiler (100 LPH and 50 PSI) has installed and operates for 4 hours in weekdays and 7 hours in weekend. Feed water to the boiler was at ambient temperature and generated steam is utilized for cooking of rice.
- Implementation of solar water heater (300 LPH) will preheat the feed water upto 50 – 65oC and also hot water can be used for cleaning the utensils, etc., This will reduce the LPG consumption by 3-5%.
- Apart from that significant organic solid waste generated as mentioned below: → Wet waste - 290 kg / day → Dry (vegetable waste) - 40 kg /day → Cooked Food - 110 kg / day → Garden Waste (Plantation) - 500 kg /day

RECOMMENDATION: 1

| | | |
|---|---|---|
| Description of Existing System and its operation | : | Present power consumption of all the AC'S is 838 kW in different Blocks |
| Description of Proposed system and its operation | : | It is recommended to check with the authorized service person to improve the performance of the AC'S |
| Energy Saving Calculations | | |
| Present power consumption (kW) | : | 838 |
| Proposed power consumption (kW) | : | 700 |
| Proposed power saving after (kW) servicing | : | 138 |
| Achievable Energy savings (kWh/Year) (100*4) | : | 55200 |
| Cost Benefits | | |
| Energy Saving Potential (kWh/Year) | = | 55200 |
| Cost Savings (INR)@ INR. 7.65 per kWh | = | 422,280 |
| Investment | = | Not considered (Since it is maintenance activity) |
| Payback Period | = | Immediate |

RECOMMENDATION: 2

| | | |
|--|---|--|
| A: Title of Recommendation | : | Retrofit T12 with LED Tube Light Lamps |
| B: Description of Existing System and its operation | : | Existing luminaries for Office lighting are T12 Lamps which consumes 36 W |
| C: Description of Proposed system and its operation | : | Retrofit T12 Tube Light's with energy efficient LED Tube Lights to reduce the energy consumption. The LED Tube Lights will consume 22 W without compromising on the illumination levels. |
| D: Energy Saving Calculations | | |
| Present No. of FTLs | | 1930 |
| Present Fixture Consumption of T12(W) | : | 36 |
| Proposed Consumption of LED Tube Light(W) | : | 22 |
| Achievable power savings(W) | : | 14 |
| Operating Hours (@ 4 hrs./day & 260 D/Y) | : | 1040 |
| Total Energy Savings kWh/year | : | 28,100 |
| E: Cost Benefits | | |
| Energy Saving Potential / year | = | 28,100 |
| Cost Savings / year@ unit cost Rs. 7.60/ unit | = | 213,566 |
| Investment (@ Rs. 500/LED) | = | 8,68,500 |
| Payback Period in months | = | 48 |